


# Adaptable Single Active Loop Thermal Control System (TCS) for Future Space Missions

*Issam Mudawar & Seunghyun Lee*

Purdue University Boiling and Two-Phase Flow Laboratory (PU-BTPFL)  
Mechanical Engineering Building, 585 Purdue Mall  
West Lafayette, IN 47907-2088

*Mohammad Hasan*

NASA Glenn Research Center  
Fluid Physics and Transport Branch  
21000 Brookpark Rd,  
Cleveland, OH 44135



Develop **Adaptable Single-Loop Thermal Control System (ASL-TCS)** that can tackle widely varying heat loads of different space missions and both cold and warm environments while improving system performance, reducing weight and volume, and ensuring reliable operation irrespective of gravity

**Thermal loads and effective sink temperatures for different missions  
based on Orion Multi-Purpose Crew Vehicle (MPCV)**

	Launch to LEO	TLC, TNEOC, TMC	LLO	LSO	NEO	MSO	LMO
Thermal Load	1.2 kW	1 kW	5 kW	6.25 kW	TBD	6.25 kW	5 kW
Effective Sink Temperature	-93 to -66°C (180 to 207K)	-198°C (75 K)	-213 to 17°C (60 to 290 K)	-56 to -34°C (217 to 239K)	TBD	-123 to -23°C (150 to 250K)	22°C (295 K)

LEO: Low Earth Orbit

**LLO: Low Lunar Orbit**

TLC: Trans Lunar Coast

TNEOC: Trans Near Earth Objects Coast

TMC: Trans Mars Coast

LSO: Lunar Surface Operation

NEO: Near-Earth Object

MSO: Mars Surface Operation

**LMO: Low Mars Orbit**

**LLO and LMO associated with heat sink temperatures that exceed lowest minimum fluid temperature of 2°C at inlet to cabin HX, therefore requiring heat pump mode**

$$T_{cabinHX,in} = 2^{\circ}\text{C}:$$

$$T_{evap} = 5^{\circ}\text{C}:$$

$$\text{Condenser pinch temp.} = 5^{\circ}\text{C}$$

$$\text{LLO: } T_{sink} = 17^{\circ}\text{C}, T_{cond,out} = 22^{\circ}\text{C}$$

$$\text{LMO: } T_{sink} = 22^{\circ}\text{C}, T_{cond,out} = 27^{\circ}\text{C}$$

$$\text{Max } T_{lift} = 80^{\circ}\text{C when } T_{evap} = 5^{\circ}\text{C (60}^{\circ}\text{C for R404a with } T_{crit} = 72.07^{\circ}\text{C)}$$

$$Q_{cabinHX} = 0.75 \text{ kW}$$

$$Q_{avionicsHX} = 0 - 5.5 \text{ kW}$$

prevent frost formation on evaporator surfaces

evaporation temperature

maintain adequate condenser performance

## Pressure:

$$\text{Max pressure} = P_{sat} \text{ at } T_{cond,sat} = T_{evap} (= 5^{\circ}\text{C}) + T_{lift} (= 80^{\circ}\text{C})$$

$$\text{Min pressure} = P_{sat} \text{ at } T_{cabinHX,in} = 2^{\circ}\text{C}$$

## Radiator Area:

$$A_{radiator,s} = A_{vapor} + A_{sat} + A_{liquid}, \quad T_{cond,sat} = T_{evap} + T_{lift}$$


$$A_{vapor} = \frac{\dot{m}_{hp} c_{p,f} (T_{cond,in} - T_{cond,sat})}{\epsilon \sigma \left\{ \left( \frac{T_{cond,in} + T_{cond,sat}}{2} \right)^4 - T_{sink}^4 \right\}}, \quad A_{sat} = \frac{\dot{m}_{hp} h_{fg}}{\epsilon \sigma \left\{ T_{cond,sat}^4 - T_{sink}^4 \right\}}, \quad A_{liquid} = \frac{\dot{m}_{hp} c_{p,f} (T_{cond,sat} - T_{cond,out})}{\epsilon \sigma \left\{ \left( \frac{T_{cond,sat} + T_{cond,out}}{2} \right)^4 - T_{sink}^4 \right\}}$$

## Coefficient of Performance:

$$COP = \frac{Q_{cabinHX} + Q_{avionicsHX}}{W_{comp} / \eta_{comp}}, \quad \eta_{comp} = 85\%$$

$$W_{comp} = \int_{P_{avionicsHX,out}}^{P_{cond,in}} V dP = \dot{m}_{hp} (h_{cond,in} - h_{avionicsHX,out})$$


## Mass Flow Rate



### Mass Flow Rate:

- LLO: Lower  $T_{cond,out}$ , lower enthalpy at inlet to cabin HX, higher evaporator enthalpy rise, lower mass flow rate
- NH<sub>3</sub> requires lowest flow rate


## Maximum and Minimum Pressure




### Pressure:

- Max pressure highest for NH<sub>3</sub>, lowest for HFE7000

## Low Lunar Orbit (LLO)




## Low Mars Orbit (LMO)




### Mass Flow Rate:

- Area decreases with increasing  $T_{\text{lift}}$
- NH<sub>3</sub> requires smallest area but area differences among fluids are small

## Low Lunar Orbit (LLO)



## Low Mars Orbit (LMO)



### COP Trends

- Decreases with increasing  $T_{\text{lift}}$  because of higher compressor work
- Higher for LLO because of lower evaporator inlet enthalpy
- Fairly equal for different fluids

**1. Chlorofluorocarbons (CFCs)**

- Consist of chlorine, fluorine and carbon
- Ex: R11, R12, R113, R114 and R115
- High ozone depletion potential (ODP)
- Already banned

**2. Hydrochlorofluorocarbons (HCFCs)**

- Consist of hydrogen, chlorine, fluorine and carbon
- Ex: R22, R123, R124 and R142b
- Small but finite ODP
- Being gradually phased out

**3. Hydrofluorocarbons (HFCs)**

- Consist of hydrogen, fluorine and carbon
- Ex: R404a, R134a, R245fa, HFE7000
- Zero ODP; low global warming potential (GWP)
- Currently preferred refrigerants

**Toxicity Rating:**

Class A: no evidence of toxicity below 400 ppm

Class B: evidence of toxicity below 400 ppm

**Flammability Rating:**

Class 1: no flame propagation in open air

Class 2: may propagate flame under certain conditions in open air

Class 3: highly flammable

	Type	Rating	Critical Pressure (MPa)	Critical Temperature (°C)
Ammonia	-	B2	11.33	132.25
R404a	HFC	A1	3.73	72.12
R134a	HFC	A1	4.06	101.06
R245fa	HFC	B1	3.65	154.01
HFE7000	HFC	A1	2.48	165.00
R123	HCFC	B1	3.66	183.68




- NH<sub>3</sub>:** Requires smallest flow rate but highest condenser pressure; exhibits toxicity and flammability
- R404a:** An HFC that requires high condenser pressure; exhibits no toxicity or flammability, zero ODP and low GWP
- R134a :** An HFC that provides compromise between reducing flow rate and reducing pressure; exhibits no toxicity or flammability, zero ODP and low GWP
- R245fa:** An HFC that provides compromise between reducing flow rate and reducing pressure; exhibits no flammability, zero ODP and low GWP, but some toxicity
- HFE7000:** An HFC that requires low condenser pressure but high flow rate; exhibits no toxicity or flammability, zero ODP and low GWP; used as replacement to R123
- R123:** An HCFC that requires low condenser pressure but high flow rate; exhibits no toxicity or flammability but some ODP

No significant differences among fluids in terms of radiator area or COP


**Preferred Coolant: R134a (1,1,1,2-Tetrafluoroethane, CH<sub>2</sub>FCF<sub>3</sub>)**

# *p-h Diagram for Heat Pump with LLSL-HX for Low Mars Orbit (LMO) using R134a*






- LLSL-HX used high temperature of subcooled liquid exiting condenser to further superheat vapor before entering compressor
- Compared to basic heat pump: 8 to 8' and 4 to 4'

# *T-S Diagram for Heat Pump with LLSL-HX for Low Mars Orbit (LMO) using R134a*



$$COP' = \frac{(Q_{\text{cabinHX}} + Q_{\text{avionicsHX}}) + \Delta Q_{\text{cooling}}}{W_{\text{comp}} + \Delta W_{\text{comp}}} = \left[ \frac{1 + \left\{ \frac{\Delta Q_{\text{cooling}}}{Q_{\text{cabinHX}} + Q_{\text{avionicsHX}}} \right\}}{\left\{ 1 + \frac{\Delta W_{\text{comp}}}{W_{\text{comp}}} \right\}} \right] COP$$

# Heat Pump with LLSL-HX versus Basic Heat Pump Mode for R134a





Low Lunar Orbit (LLO)  
Low Mars Orbit (LMO)

**Mass Flow Rate:** appreciable reduction with LLSL-HX

**COP:** some degradation with LLSL-HX



**Radiator Area:** some improvement with LLSL-HX






	Max. Heat Load, Q (kW)	Max. Heat Flux, q" (W/cm <sup>2</sup> )	Overall Dimensions	Number of Mini-Channels	Expected Pressure Drop (by correlation)
<b>Cabin HX</b>	0.75 kW	3.13	Length : 152.4 mm (6") Width : 152.4 mm (6")	75	1.26 psi
<b>Avionics HX</b>	5.5 kW (LSO/MSO)	4.58	Length: 609.6 mm (24") Width: 203.2 mm (8")	100	6.34 psi






# *Heat Transfer Characteristics and Dryout Effects*









- **Intermittent Dryout:** mostly in liquid film surrounding elongated slug flow bubble or due to vapor blanket formation within the liquid slug
- **Incipient Dryout:** dry wall patches in annular film
- **Dryout Completion:** annular flow replaced by mist flow, with cooling provided only by droplet deposition


(i)  $x_e < 0.36$



(ii)  $0.36 < x_e < 0.50$



(iii)  $0.50 < x_e < 0.74$



**Macro-channel:**

*Chen (1966)*

*Liu & Winterton (1961)*

**Mini/Micro-channel:**

*Lazarek & Black (1982)*

*Tran et al. (1996)*


*Kandlikar (2004)*

*Lee & Mudawar (2005)*

*Bertsch et al. (2009)*

*Kim & Mudawar (2014)*

# Comparison of Present Average Two-Phase Heat Transfer Coefficient with Predictions of Universal Methodology



**Consolidated database:  
10,805 saturated boiling heat transfer  
coefficient data points from 37 sources**

- Working fluid:  
FC72, R11, R113, R123, R1234yf, R1234ze, R134a,  
R152a, R22, R236fa, R245fa, R32, R404A, R407C,  
R410A, R417A, CO<sub>2</sub>, water
- Hydraulic diameter:  
 $0.19 < D_h < 6.5 \text{ mm}$
- Mass velocity:  
 $19 < G < 1608 \text{ kg/m}^2\text{s}$
- Liquid-only Reynolds number:  
 $57 < Re_{fo} < 49,820$
- Flow quality:  
 $0 < x < 1$
- Reduced pressure:  
 $0.005 < P_R < 0.69$

Kim & Mudawar, *Int. J. Heat Mass Transfer* 64  
(2013) 1239-1256

$$h_{tp} = (h_{nb}^2 + h_{cb}^2)^{0.5}$$

For nucleate boiling dominant regime :

$$h_{nb} = \left[ 2345 \left( Bo \frac{P_H}{P_F} \right)^{0.70} P_R^{0.38} (1 - x_e)^{-0.51} \right] \left( 0.023 Re_f^{0.8} Pr_f^{0.4} \frac{k_f}{D_h} \right)$$

For convective boiling dominant regime :

$$h_{cb} = \left[ 5.2 \left( Bo \frac{P_H}{P_F} \right)^{0.08} We_{fo}^{-0.54} + 3.5 \left( \frac{1}{X_{tt}} \right)^{0.94} \left( \frac{\rho_g}{\rho_f} \right)^{0.25} \right] \times \left( 0.023 Re_f^{0.8} Pr_f^{0.4} \frac{k_f}{D_h} \right)$$

where  $Bo = \frac{q''_H}{G h_{fg}}$  ,  $P_R = \frac{P}{P_{crit}}$  ,  $Re_f = \frac{G(1 - x_e) D_h}{\mu_f}$

$$We_{fo} = \frac{G^2 D_h}{\rho_f \sigma}$$
 ,  $X_{tt} = \left( \frac{\mu_f}{\mu_g} \right)^{0.1} \left( \frac{1 - x_e}{x_e} \right)^{0.9} \left( \frac{\rho_g}{\rho_f} \right)^{0.5}$


$q''_H$ : effective heat flux averaged over heated perimeter of channel

$P_H$ : heated perimeter of channel




$P_F$ : wetted perimeter of channel


# Universal Predictive Methodology for Saturated Flow Boiling Heat Transfer in Small Diameter Tubes

Nucleate Boiling Dominant Data




Convective Boiling Dominant Data





**Parallel channel instability:** Small amplitude, high frequency pressure drop oscillations  
 (4,000 - 10,000 Pa over period of 1.33 s )





**Discrete Fourier transform:** pressure drop response in frequency domain  
 (power spectrum peak of 0.74 Hz ( $\sim 1.33$  sec))